

SSO Notification List												
December 2009												
Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
1	12/1/2009	2500 W. Franklin Street	21223	Rags & Grease	Inner Harbor	0:17	11:08 PM - 11:25 PM	Sewer Water	51	Jetted M/L choke with Pressure Truck	Turned over to be CCTV'ed	103344
2	12/1/2009	1605 Aliceanna Street	21231	Pipe Break	Inner Harbor	7:30	2:30 PM - 10:00 PM	Gray Water	2,250	Replaced Broken Pipe	No Preventive Actions Required	103322
3	12/4/2009	1000 N. Bond Street	21205	Debris	Inner Harbor	1:33	3:47 PM - 5:20 PM	Sewer Water	279	Jetted M/L choke with Pressure Truck	Turned over to be CCTV'ed	103424
4	12/7/2009	4803 Robertson Ave	21206	Rags	Herring Run	1:30	12:30 PM - 2:00 PM	Gray Water	900	Jetted M/L choke with Pressure Truck	No Preventive Actions Required	103501
5	12/8/2009	1 Edgevale Road	21210	Debris	Jones Falls	3:47	2:13 PM - 6:00 PM	Sewer Water	2,270	Jetted M/L choke with Pressure Truck	Turned over to be CCTV'ed	103550
6	12/9/2009	1820 E. Eager Street	21205	Heavy Rain	Inner Harbor	2:45	8:00 AM - 10:45 AM	Heavy Water	16,500	Due to I/I caused by Heavy Rain, wait for rain to subside.	No Preventive Actions Required	64874
7	12/9/2009	1 N. Bethel Street	21231	Heavy Rain	Inner Harbor	3:45	7:00 AM - 10:45 AM	Gray Water	9,000	Due to I/I caused by Heavy Rain, wait for rain to subside.	No Preventive Actions Required	64864
8	12/9/2009	1730 E. Chase Street	21213	Heavy Rain	Inner Harbor	2:45	8:00 AM - 10:45 AM	Heavy Gray Water	12,375	Due to I/I caused by Heavy Rain, wait for rain to subside.	No Preventive Actions Required	64896
9	12/9/2009	401 Eager Street	21202	Heavy Rain	Jones Falls	5:07	7:53 AM - 1:00 PM	Heavy Gray Water	42,980	Due to I/I caused by Heavy Rain, wait for rain to subside.	No Preventive Actions Required	64873
10	12/9/2009	1700 Falls Road	21201	Heavy Rain	Jones Falls	4:17	8:43 AM - 1:00 PM	Heavy Gray Water	12,850	Due to I/I caused by Heavy Rain, wait for rain to subside.	No Preventive Actions Required	64882
11	12/9/2009	1300 E. Lombard Street	21202	Roots	Inner Harbor	12:00	8:00 AM - 8:00 PM	Gray Colored Water	3,600	Relieved M/L choke with Pressure Machine	Turned over to be CCTV'ed	103604
12	12/12/2009	641 W. University Pkwy	21210	Roots	Jones Falls	4:00	12:00 PM - 4:00 PM	Heavy Gray Water	240	Relieved M/L choke with Pressure Machine	Turned over to be CCTV'ed	103713
13	12/13/2009	500 W 40th Street	21210	Rags, Roots & Grease	Jones Falls	1:00	7:00 PM - 8:00 PM	Heavy Gray Water	300	Relieved M/L choke with Pressure Machine	Turned over to be CCTV'ed	103738
14	12/17/2009	949 Hillen Street	21202	Rags & Grease	Jones Falls	4:00	7:00 AM - 11:00 AM	Gray Colored Water	240	Relieved M/L choke with Pressure Truck	Turned over to be CCTV'ed	103870
15	12/17/2009	403 Old Orchard Road	21229	Rags, Roots & Grease	Gwynns Falls	4:18	11:55 AM - 4:13 PM	Heavy Gray Water	1,290	Relieved M/L choke with Pressure Truck	Turned over to be CCTV'ed	103882

Serial No.	Date of Occurrence	Location	Zip Code	Reason	Stream Affected	Duration (Hrs:Min)	Time	Description of Discharge	Est. Quantity of Discharge (gallons)	Measures taken to Minimize Discharge	Preventive Action to Stop Recurrence	Work Order #
16	12/17/2009	3700 Keswick Road	21211	Rags	Jones Falls	1:00	1:09 PM - 2:09 PM	Heavy Gray Water	180	Relieved M/L choke with Pressure Truck	Turned over to be CCTV'ed	103879
17	12/18/2009	501 W 40th Street	21210	Roots & Grease	Jones Falls	1:00	10:00 AM - 11:00 AM	Heavy Gray Water	300	Relieved M/L choke with Pressure Truck	Turned over to be CCTV'ed	103902
18	12/22/2009	501 W. University Pkway	21210	Rags, Roots & Grease	Jones Falls	2:00	11:13 AM - 1:13 PM	Heavy Gray Water	840	Relieved M/L choke with Pressure Truck	Turned over to be CCTV'ed	103985
19	12/22/2009	3308 N. Hilton Street	21215	Trash	Gwynns Falls	Undetermined	Undetermined	Paper debris on sidewalk	Evidence of Overflow	Pay loader removed cables from c/o	Turned over for further investigation	104002
20	12/22/2009	2142 Parksley Ave	21230	Debris	Inner Harbor	4:41	2:51 PM - 7:32 PM	Sewer Water	1,967	Jetted M/L choke with Pressure Truck	Turned over to be CCTV'ed	103996
21	12/22/2009	1658 Ramblewood Road	21239	Rags, Trash & Grease	Herring Run	4:00	10:00 AM - 2:00 PM	Gray and Brown Colored Water	720	Jetted M/L choke with Pressure Truck	Turned over to be CCTV'ed	103984
22	12/26/2009	1 N. Bethel Street	21231	Heavy Rain	Inner Harbor	2:00	4:34 PM - 6:34 PM	Heavy Gray Water	3,000	Due to I/I caused by Heavy Rain, wait for rain to subside.	No Preventive Actions Required	104105
23	12/27/2009	1805 E 33rd Street	21218	Rags, Roots & Grease	Herring Run	0:35	9:40 AM - 10:15 AM	Sanitary Water, Grease, Rags & Roots	35	Relieved H/C with Electric Cutting Machine	Turned over to be CCTV'ed	104127
24	12/27/2009	5103 Harford Road	21214	Rags & Grease	Herring Run	0:15	3:20 PM - 3:35 PM	Sanitary Water, Rags & Grease	15	Relieved H/C with Electric Cutting Machine	Turned over to be CCTV'ed	104137
25	12/27/2009	5200 Kelway Road	21239	Rags & Roots	Herring Run	0:15	9:00 AM - 9:15 AM	Rags & Roots	45	Jetted M/L choke with Pressure Truck	Turned over to be CCTV'ed	104124
26	12/28/2009	3619 Old York Road	21218	Rags & Grease	Herring Run	3:29	4:21 PM - 7:50 PM	Sewer Water	25	Relieved H/C with Drain Cleaning Machine	Turned over to be CCTV'ed	104192
27	12/28/2009	2500 W. Franklin Street	21223	Rags & Grease	Inner Harbor	0:29	6:10 PM - 6:39 PM	Sewer Water & Grease	290	Jetted M/L choke with Pressure Truck	Turned over to be CCTV'ed	104190
								TOTAL	112,542			